



FORM VI
DIRECTORATE OF FACTORIES & BOILERS, ODISHA
CERTIFICATE FOR USE OF A BOILER
(Renewal)
(Regulation 389)

Registry Number of Boiler : **OD-522** Type of Boiler : **H.M.T**
Boiler Rating : **150.0** Place and Year of manufacture :
TIRUCHIRAPPAL
LI, 2021
Maximum Continuous Evaporation : **4500.0 kg/hr**
Name of Owner : **M/s . D.K. RICE MILL (P) LTD.**
Situation of Boiler : **AT/PO-NUNMATH,VIA-KESINGA,DIST-**
KALAHANDI,ODISHA, Dist- Kalahandi

Repairs : ---

Remarks :

Hydraulically tested on **04/01/2024** to **14.0 kg/cm²**

I hereby certify that the above described Boiler is permitted by me under the provisions of Section 7/8 of the Boiler Act No. V of 1923 to be worked at a maximum pressure **10.54 kg/cm²** for the period from **04/01/2024** to **03/01/2025**

The loading of the **Spring loaded** safety valve is not to exceed **10.54 kg/cm²**

Fees Rs.**4500.0**

Paid on. : **28/11/2023**

Dated at **Kalahandi**

This **6th** day of **January** 2024

Inspector of Boilers, Kalahandi

NOTE :

- (i) This is a digitally signed electronically generated certificate and therefore needs no ink-signed signature.
- (ii) This certificate is issued as per section 4, 5 & 6 of IT Act 2000 and its subsequent amendments in 2008.
- (iii) For verification, visit <https://pareshram-labour.odisha.gov.in>
- (iv) Tampering of this certificate will attract penal action.

Conditions

1. No structural alternation, addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act
2. Under the provision of section 8 of the Act this certificate shall cease to be in force:
 - a) on the expiry of the period for which, it was granted, or
 - b) when any accident occurs to the boiler; or
 - c) when the boiler is moved, the boiler not being a vertical boiler the heating surface of which is less than two hundred square feet, or a portable or vehicular boiler, or
 - d) same as provided in section 12 of the Act, when any structural alternation, addition or renewal is made in or to the boiler; or
 - e) if the chief inspector in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam pipe attached to the boiler; or
 - f) on the communication to the owner of the boiler of an order of the Chief Inspector or Inspector prohibiting its use on the ground that it or any boiler unproduced or any steam pipe attached there to is in a dangerous condition

Under section 10 of the Act when the period of a certificate relating to a boiler has expired, the owner shall provide that he/she has applied before expiry of that period for renewal of the certificate, be entitled to use the boiler at the maximum pressure entered in the former certificate pending the issue of orders on the application but this shall not be deemed to authorize the use of a boiler in any of the cases referred to clauses (b),(c),(d),(e) and (f) of sub section (1) of section 8 occurring after the expiry of the period of the certificate

3. The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.
4. The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working

NOTE :

- (i) This is a digitally signed electronically generated certificate and therefore needs no ink-signed signature.
- (ii) This certificate is issued as per section 4, 5 & 6 of IT Act 2000 and its subsequent amendments in 2008.
- (iii) For verification, visit <https://pareshram-labour.odisha.gov.in>
- (iv) Tampering of this certificate will attract penal action.